

PUBLIC/PRIVATE SCHOOL

STATE OF FLORIDA DEPARTMENT OF HEALTH COUNTY HEALTH DEPARTMENT PUBLIC/PRIVATE SCHOOL INSPECTION REPORT



Geocoded 25.651992/-80.313033

- PURPOSE:**
- REINSPECTION
 - ROUTINE
 - CHANGE OF OWNER
 - CONSTRUCT.
 - CONSULTATION
 - COMPLAINT
 - EPIDEMIOLOGY
 - QA SURVEY
 - PREOPENING
 - OTHER

TYPE: Public School

CENSUS	FEMALES	MALES
1083	483	600

RESULTS:

- Satisfactory
- Incomplete
- Unsatisfactory
- OUT OF BUSINESS

NAME Palmetto Middle School

ADDRESS 7351 SW 128 Street **CITY** Miami

OWNER M-DCSB Food and Nutrition **ZIP** 33156

PERSON IN CHARGE Randall Cromer **PHONE** (305) 238-1453

E-MAIL Imacosta@dadeschools.net

- Correct Violations by**
- Next Inspection
 - 8:00 AM on

BEGIN TIME	END TIME	DATE ASSESSED	POSITION #	EXISTING FACILITIES - PERMIT NUMBER
08:00	10:00	09/26/2014	27431	13-51-08240

RE-INSPECTION DATE

As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.

SCHOOL SANITATION

- 1. School Site
- 2. Playground Equipment
- 3. Athletic Equipment

- 8. Natural Ventilation
- 9. Mechanical Ventilation
- 10. Provided/Accessible

- 15. Handwash Facilities
- 16. Showers/Fixtures
- 17. Shower Water Temp.

- LIQUID/SOLID WASTE**
- 21. Sewage Disposal
 - 22. Solid Waste

- SAFETY**
- 26. First Aid Kit

BUILDINGS

- 4. Construction
- 5. Maintenance & Repair
- 6. Lighting/Foot-Candles
- 7. Heating, Ventilation, A/C

- SANITARY FACILITIES**
- 11. Cleanliness & Repair
 - 12. Toilet Facilities
 - 13. Separation of Sexes
 - 14. Fixture Ratio

- WATER SUPPLY**
- 18. Installed/Operated/Maintained
 - 19. Drinking Fountains
 - 20. Approved Source

- VECTOR/VERMIN CONTROL**
- 23. Infestation/Control
 - 24. Brush/Trash
 - 25. Water Collection/Drainage

- FOOD**
- 27. Food Insp. Rpt.
- OTHER**
- 28.
 - 29.

COMMENTS AND INSTRUCTIONS

Violation #5 Replace burned out bulb's throughout the school.
Code Reference FAC: Maintenance & Repair 64E-13.004(3)(b)(c). Buildings shall be kept clean and in good repair, free from hazardous conditions, such as loose or broken floor tiles and boards; loose moldings; loose hanging fixtures, pipes, and electric wires; and broken plaster. Furnishings and equipment shall be kept clean and in good repair, free of missing parts and hazards such as sharp edges, splinters, and protruding or rusty nails.

Violation #19 Repair water fountain by room 122.
Code Reference FAC: Drinking Fountains 64E-13.004(7)(b). Drinking fountains of an approved, sanitary slant jet type shall be provided in the ratio specified in the local building code or Chapter 64E-10, F.A.C. In no case shall fountains be located in any toilet room.

Violation #23 Evidence of roaches in boy's restroom 1st floor. Effective measures must be taken.
Code Reference FAC: Infestation/Control 64E-13.004(10). Effective measures shall be used to prevent harborage, propagation, or infestations of rodents and all insects.

INSPECTION CONDUCTED BY: Manuel Alzugaray **PHONE:** 305 623-3500

INSPECTION COND SIGNATURE: *M. Alzugaray* **PHONE 2:** _____

COPY OF REPORT RECEIVED BY: *Randall Cromer* **DATE:** 9/26/2014

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY PUBLIC HEALTH UNIT
Public/Private School



Name: Palmetto Middle School

Date: 09/26/2014

Identification No: 13-51-08240

Comments and Instructions (Continued from Page 1):

Copy of Report
Received By:

Inspector Manuel Alzugaray

Page 2